

**Tender: 2019-31-T Bathroom and Kitchenette Renovations**

---

**To All Bidders:**

**General:**

- This addendum shall be read in conjunction with the original Tender documents.
- Where inconsistent with the above, this addendum shall govern.
- No consideration shall be allowed for increases (extras) to the Tender Price, or otherwise to modify the Tender Submission, due to any failure of the Vendors being familiar with this addendum.
- The Bidder should insert in the Bid Form the numbers of addenda received by her/him during the Tender period. This addendum forms an integral part of the Tender Submissions and is included therein.
- It is the Bidder's responsibility to ensure all addenda have been received by the Bidder prior to Tender closing.

**Scope of this Addendum:**

**Please note answer/clarification to Question from prospective Bidder:**

1. The Washroom Accessory Schedule note TP1 – Toilet Partitions Description states “No sight-line solution with embossed stainless steel finish - full height floor-ceiling mounted” however the drawings show standard height-wall mounted toilet partitions. Please clarify.

**Response:** The Washroom Accessory Schedule TP1 Description is to be replaced with “No sight-line solution with embossed stainless steel finish - standard height-wall mounted”.

**Attachments:**

**Senior Procurement : Nicole Bishop**

**Date: December 4, 2019**