

Tender: 2019-31-T Bathroom and Kitchenette Renovations

To All Bidders:

General:

- This addendum shall be read in conjunction with the original Tender documents.
- Where inconsistent with the above, this addendum shall govern.
- No consideration shall be allowed for increases (extras) to the Tender Price, or otherwise to modify the Tender Submission, due to any failure of the Vendors being familiar with this addendum.
- The Bidder should insert in the Bid Form the numbers of addenda received by her/him during the Tender period. This addendum forms an integral part of the Tender Submissions and is included therein.
- It is the Bidder's responsibility to ensure all addenda have been received by the Bidder prior to Tender closing.

Scope of this Addendum:

Please note answer/clarification to Question from prospective Bidder:

1. Addendum # 6 states the toilet partitions are to be "standard height-wall mounted". Please advise what is meant by standard height. As well, wall mounted is not a valid mounting option for these toilet partitions.

Response: The height of the existing toilet partitions is 82". They are headrail braced, floor mounted and attached to the wall in various places. The new toilet partitions must be the same height and attached similarly as shown in the below attachment.

Attachments:

Senior Procurement : Nicole Bishop

Date: December 5, 2019

